

Tuesday, April 28, 2009

This letter is to certify that the BWA Water Additives antiscalants Flocon 135 and Flocon 260 have been approved for use with Hydranautics polyamide RO membranes. This approval is contingent upon the plant operating within the antiscalant dose rates specified by BWA for the project.

This information is intended to indicate that these chemicals are not harmful to the Hydranautics membranes when used at recommended levels. Hydranautics does not warrant the performance or effectiveness of the products for preventing fouling of our membrane.

Over the years, Hydranautics has worked closely with many of the specialty membrane chemical manufacturers and suppliers, and we have found many of these products to be highly effective and safe to use. However, as a matter of policy, Hydranautics does not endorse any particular company or product. We trust that you understand that the use of any chemical that impairs membrane performance or that is ineffective is the responsibility of the owner/operator and that Hydranautics has no responsibility or liability in such event.

Regards,



**Ryan Furukawa**

Group Leader – Technical Support  
Hydranautics – A Nitto Denko Company  
401 Jones Rd.  
Oceanside, CA 92058  
E-mail: [rfurukawa@hydranautics.com](mailto:rfurukawa@hydranautics.com)  
Ph: +760.901.2679  
Ph: 1.800.CPA.PURE  
Fx: +760.901.2664  
[www.membranes.com](http://www.membranes.com)